PRODUCT DATA SHEET

Published: 2026-10-05

Hose set
G 1", 50 m
Part Number: A000007

Features

- Includes 2 hoses and 4 sets of fittings

Technical Features	
Operating temperature range	-15 ... 60 °C
Connection 1 thread (outer)	1"
Connection 2 thread (outside)	1"
Inner diameters	25 mm
Outer diameter	33 mm
Insulation thickness	9 mm
Material	EPDM

Reserve technical changes

LAUDA DR. R. WOBSER GMBH & CO. KG
Laudaplatz 1 • 97922 Lauda-Königshofen • DE

T + 49 (0) 9343 503-0
info@lauda.de • www.lauda.de
WEEE-Reg-Nr.: DE 66 42 40 57

Kommanditgesellschaft: Sitz Lauda-Königshofen
Registergericht Mannheim • HRA 560069

Persönlich haftende Gesellschafterin:
LAUDA DR. R. WOBSER Verwaltungs-GmbH
Sitz Lauda-Königshofen
Registergericht Mannheim • HRB 560226

Geschäftsführer:
Dr. Gunther Wobser (Vors.),
Dr. Marc Stricker
Beirat: Dr. Gerhard Wobser

PRODUCT DATA SHEET

Published: 2026-10-05

Hose set

G 1", 50 m

Part Number: A000007

CHILLER SIDE

WATER INLET

1 X HOSE CARRIER
FLEXIBLE PIPE
1 X CLAMP
THERMAL INSULATION
INSULATION TAPE

APPLICATION SIDE

WATER INLET

1 X HOSE CARRIER
1 X CLAMP
1 X FEMALE- FEMALE

WATER OUTLET

1 X HOSE CARRIER
FLEXIBLE PIPE
1 X CLAMP
THERMAL INSULATION
INSULATION TAPE

WATER OUTLET

1 X HOSE CARRIER
1 X CLAMP
1 X FEMALE- FEMALE

Loctite 55

Reserve technical changes

LAUDA DR. R. WOBSER GMBH & CO. KG
Laudaplatz 1 • 97922 Lauda-Königshofen • DE

T + 49 (0) 9343 503-0
info@lauda.de • www.lauda.de
WEEE-Reg-Nr.: DE 66 42 40 57

Kommanditgesellschaft: Sitz Lauda-Königshofen
Registergericht Mannheim • HRA 560069

Persönlich haftende Gesellschafterin:
LAUDA DR. R. WOBSER Verwaltungs-GmbH
Sitz Lauda-Königshofen
Registergericht Mannheim • HRB 560226

Geschäftsführer:
Dr. Gunther Wobser (Vors.),
Dr. Marc Stricker
Beirat: Dr. Gerhard Wobser